

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name KFC	Date 10/15/19
Location Grand Central Horseheads (V), NY	Permit # NYR11E218
Weather Conditions sunny	Entry Time: 2:00pm
On-Site Representative Present: no one on site	Exit Time: 2:10 pm

Construction Site Notes:

-Building is still under construction.
-Some work is completed on the stormwater pond but not all that was approved.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X			Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:

-Stormwater basin has not been completed.
-Some areas around the store have been stabilized. Other areas are still bare.

Satisfactory	Marginal	X	Unsatisfactory
Date	Inspector		



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	KFC Village of Horseheads Municipal Construction Insp. October 15, 2019
BY:	Jessica Verrigni, CPESC, CPSWQ



Some areas have been hydroseeded and grass is growing.



Outlet pipe has been installed into the stormwater pond.



Woody vegetation has not been removed from the stormwater pond.



Drainage swale does not look like it has been established to the stormwater pond.