



851 Chemung Street
Horseheads, New York 14845

June 18, 2015

Robert Young, Code Enforcement Officer
Village of Horseheads Code Enforcement Office
202 S. Main Street
Horseheads, NY 14845

**RE: Villas at Gardner Road Phase 1
Lyndhurst Avenue Extension Horseheads, New York
Review of Erosion and Sediment Control Plan**

Mr. Young,

I have completed a review of the above referenced project regarding the Stormwater Pollution Prevention Plan/ Erosion and Sediment Control Plan for that project. The following information was reviewed:

- Stormwater Pollution Prevention Plan for proposed Phase 1 of Villas at Gardner Road, Stamped by a Professional Engineer, Prepared by Fagan Engineers, Dated May 2015, Received June 1, 2015

Based on my review of the above information, I believe that the Erosion and Sediment Control Plan is consistent with the Village of Horseheads' Erosion and Sediment Control Ordinance. This acceptance is conditioned upon the following:

1. This SWPPP is only for Phase 1, the initial clearing/investigation of the property to evaluate the properties potential for future development.
2. This approval is only for the erosion and sediment control portion of this project and is not for any post construction stormwater management practices. This erosion and sediment control plan will need to be updated once the proposed development plan is written to comply with the Villages' Stormwater Management Ordinance.
3. Once the initial clearing and investigation is completed, the entire site must be stabilized in accordance with the approved SWPPP.

If you have any comments or questions regarding this letter please feel free to contact me.

Sincerely,

A handwritten signature in blue ink that reads "Jessica Verrigni". The signature is written in a cursive, flowing style.

Jessica Verrigni, CPESC, CPSWQ

Cc: Jimmie Joe Carl, P.E.
Fagan Engineers