

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Villa's	Date 4-11-22
Location Royal Court Horseheads, NY	Permit # NYR11P622
Weather Conditions sunny	Entry Time: 11:35 am
On-Site Representative Present:	Exit Time: 11:39_ am

Construction Site Notes:	
	-No lots under construction at this time.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X			Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
	-Old Silt fence needs to be removed especially from the drainage swale.

Satisfactory x Marginal Unsatisfactory

Date 4/11/22	Inspector Jessica Verugni
---------------------	----------------------------------