





**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
**851 Chemung Street**  
**Horseheads, New York 14825**  
**Ph. 607.796.2216**

<b>PROJECT:</b>	Villa's at Gardner Rd. Village of Horseheads Municipal Construction Inspection December 5, 2018
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ




Pavement has been completed since the last municipal inspection.



Center island has not been stabilized.



Channel erosion is occurring into the stormwater forebay.- no correction has been made.



Erosion into CB3 is still occurring and no correction has been made.