



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Villa's (Royal Court)
Village of Horseheads
Municipal Inspection
November 2, 2021

BY: Jessica Verrigni, CPESC, CPSWQ



Compacted areas will not grow grass. Decompaction and stabilization required.



Compacted areas will not grow grass. Decompaction and stabilization required.



Silt fence is installed in those weeds across the drainage swale. It must be removed.



Silt fence across ditch (photo from April 2021) that need to be removed from drainage swale.