



CHEMUNG
COUNTY
STORMWATER
COALITION

851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Horseheads Hotel
Village of Horseheads
Municipal Inspection
April 30, 2015

BY Jessica Verrigni, CPESC, CPSWQ



Area that has been seeded- If vegetation does not start within 1 week, fresh seed with hay mulch needs to be applied.

Stormwater detention facility is too deep at this time but not at final grade.



Fabric over storm grate needs to be removed.

Grass is establishing on some open soil areas.