





CHEMUNG  
COUNTY  
STORMWATER  
COALITION

851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

<b>PROJECT:</b>	Horseheads Hotel
	Village of Horseheads
	Municipal Inspection
	June 29, 2015

<b>BY</b>	Jessica Verrigni, CPESC, CPSWQ
-----------	--------------------------------



Storm sewers were installed but not the catch basins.



Areas outside of the work zone (other side of silt fence) require stabilization.



Infiltration basin was not supposed to be constructed until the end of the project. Any silt accumulation will need to be cleaned out of it prior to termination of permit coverage.



Corrections to drop inlet protection were completed.