




COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Horseheads Hotel
Village of Horseheads
Municipal Construction Inspection
August 21, 2016

BY: Jessica Verrigni, CPESC, CPSWQ



Silt fence requires replacement and repair.



Silt fence requires replacement and repair.



Concrete washed onto the ground.



Concrete washed onto the ground.