



Project Name	Best Western/Village Hotel	Date	12-19-16
Location	SR Horseheads	Permit #	NYR10Y122
Weather Conditions	cold, sunny	Entry Time:	10:31 am
On-Site Representative Present:	none	Exit Time:	10:46 am

Construction Site Notes:

	-hotel is under construction. No earth work being completed at this time-ground frozen.

Yes	No	N/A	
	X		All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
	X		Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

-silt fence has been replaced.
-open soil sitting idle has not been stabilized. (Most areas are gravel.)

Satisfactory	Marginal	X	Unsatisfactory
Date	12/19/16	Inspector	Jessica Herrig



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
**851 Chemung Street**  
**Horseheads, New York 14825**  
**Ph. 607.796.2216**

**PROJECT:** Horseheads Hotel  
Village of Horseheads  
Municipal Construction Inspection  
December 19, 2016

**BY:** *Jessica Verrigni, CPESC, CPSWA*



Drop inlet protection not installed correctly.



Silt fence has been replaced.

