


COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Horseheads Hotel
Village of Horseheads
Municipal Inspection
January 29, 2020

BY: Jessica Verrigni, CPESC, CPSWQ



Concrete washout needs to be replaced before the next concrete pour. It is past 50% capacity.



Construction entrance is installed but with warm weather more tracking will occur from employee parking. Monitor and make corrections as needed.



Catch basin inlet protection needed.



Catch basin protection needed especially from the concrete curb that will be poured next to it.