

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Horseheads Hotel (Best Western)	<b>Date</b> 12/16/2021
<b>Location</b> SR 14 Horseheads (V)	<b>Permit #</b> NYR10Y122
<b>Weather Conditions</b> sunny, cool	<b>Entry Time:</b> 9:11 am
<b>On-Site Representative Present:</b> Bob Young, Jamie Burgess (Village representative)	<b>Exit Time:</b> 9:40 am

Construction Site Notes:	
	Hotel is still under construction but first coat of binder has been put down in parking lots.

Yes	No	N/A	
	x		All erosion and sediment control measures installed/constructed
		x	All erosion and sediment control measures maintained properly
	x		Are there currently more than 5 acres disturbed w/o prior approval
	x		Have stabilization measures been initiated in inactive areas
x			Are permanent stormwater control measures being implemented
	x		Was there a discharge into the receiving water on the day of inspection
	x		Evidence of turbidity or oil in the receiving waters
?			Are weekly inspections being performed?
?			Are the inspections being performed by a qualified individual?

Corrections Needed:
<b>Drop inlet protection</b> needs to be installed on all catch basins.
<b>Soil Stabilization-</b> All open bare soil sitting idle is to be stabilized immediately.
<b>Concrete washout-</b> bags of concrete are being mixed on site in close proximity to a storm drain. Where is equipment being washed out?
<b>Concrete Curb at STMH #8</b> has been cut or not poured. This is not an area where an open curb was proposed. Curb needs to be built behind STMH #8
<b>Qualified Inspections</b> weekly inspections are required for this project. Where are the inspection reports?

Satisfactory	Marginal	Unsatisfactory	X
<b>Date</b> 12/16/21	<b>Inspector</b> Jessica Verrognie		



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Horseheads Hotel  
Village of Horseheads  
Municipal Construction Inspection  
December 16, 2021

**BY:** Jessica Verrigni, CPESC, CPSWQ



Curb is cut at this location and is required to be behind ST MH #8. Drainage needs to be directed into the storm drain.



Soils are being driven on continuously and decompaction will be necessary before final stabilization.



Concrete being mixed on sidewalk. There is no concrete washout. This area is within 50 feet of an open storm drain.



All storm drains require inlet protection to prevent sediment, concrete, garbage and other pollutants from getting in them.



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

<b>PROJECT:</b>	Horseheads Hotel Village of Horseheads Municipal Construction Inspection December 16, 2021
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



All bare soil is to be stabilized.

All bare soil is to be stabilized.

