

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Horseheads Hotel (future Best Western)	<b>Date</b> 6-28-2022
<b>Location</b> Horseheads, NY	<b>Permit #</b> NYR10Y122
<b>Weather Conditions</b> sunny warm	<b>Entry Time:</b> 10:57 am
<b>On-Site Representative Present:</b> none	<b>Exit Time:</b> 11:06 am

Construction Site Notes:

-Concrete curb was repaired at front of parking lot and now directs water into catch basin.
-Grading of soil has occurred since last inspection on 6/6/2022.

Yes	No	N/A		
	x		All erosion and sediment control measures installed/constructed	
	x		All erosion and sediment control measures maintained properly	
		X	Are there currently more than 5 acres disturbed w/o prior approval	
	x		Have stabilization measures been initiated in inactive areas	
x			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:

- Soil needs to be stabilized to prevent erosion from occurring.
-Stormwater basin needs to have all woody and weedy vegetation removed. This basin needs to be protected from soil getting into it from areas in close proximity.

Satisfactory	Marginal	x	Unsatisfactory
<b>Date</b> 6/28/22	<b>Inspector</b> <i>Jessica Verugni</i>		



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

<b>PROJECT:</b>	Horseheads Hotel
	Village of Horseheads
	Municipal Inspection
	June 28, 2022
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Repaired concrete curb.



Open soil needs to be stabilized and stormwater basin protected from sediment.



Open soil needs to be stabilized.



Soil around the entire site needs to be protected from erosion so that sediment doesn't get into the storm system.