

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Byrne Dairy	<b>Date</b> 11/1/2021
<b>Location</b> South Ave Elmira, NY	<b>Permit #</b> NYR111426
<b>Weather Conditions</b> cool, sunny	<b>Entry Time:</b> 1:55 pm
<b>On-Site Representative Present:</b> None	<b>Exit Time:</b> 2:06 pm

Construction Site Notes:	
	-Construction is completed on the building. Awaiting final stabilization

Yes	No	N/A	
		X	All erosion and sediment control measures installed/constructed
		X	All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:
-There are large areas around the infiltration basin and along Penn. Ave that there is minimal vegetation growing. These areas will most likely need help in the Spring of 2022.
-The rock channel at the south end of the infiltration basin is not located where approved within the SWPPP. The stones also look as though they sit higher than the pavement and water may flow around the channel.
-Behind the store is extremely wet due to the time of year. However, it appears some sort of small equipment continues to drive over it and further compact the soil. If this becomes an issue of grass not growing or a runoff issue it will need to be addressed.

Satisfactory	Marginal	X	Unsatisfactory
<b>Date</b> 11/1/21	<b>Inspector</b> <i>Jessica Verigne</i>		



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Byrne Dairy  
City of Elmira  
Municipal Inspection  
November 5, 2021

**BY:** Jessica Verrigni, CPESC, CPSWQ



Areas not growing any grass may need to be addressed in the Spring 2022



Areas not growing any grass may need to be addressed in the Spring 2022



Looks like mowers are driving in this area when it is wet. They are rutting the area up and compacting the soil.



Grass is not growing in numerous areas which may need to be addressed in 2022. This includes all areas like this that could negatively impact drainage plan.



**COUNTY OF CHEMUNG**  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Byrne Dairy  
City of Elmira  
Municipal Inspection  
November 5, 2021

**BY:** Jessica Verrigni, CPESC, CPSWQ



Areas not growing any grass may need to be addressed in the Spring 2022.



Rock channel is not shaped or located according to the plan. Also, rocks are placed higher than the pavement which may divert stormwater runoff.

