

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Hilliard Warehouse Expansion	Date 10-25-2021
Location College Ave Elmira, NY	Permit # NYR111586
Weather Conditions clear, cool	Entry Time: 10:14 am
On-Site Representative Present: Dave Squires, Wenzel Construction	Exit Time: 10:25 am

Construction Site Notes:	
	-Installation of drainage around building to collect roof runoff was being installed at the time of my visit.
	-Changes to the SWPPP have been made due to existing utility location.
	-Updated SWPPP is requested

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
		X	Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
	-Changes to the approved SWPPP need to be submitted to the Stormwater Coalition Office



Satisfactory	X	Marginal	Unsatisfactory
Date	10/25/21	Inspector	Jessica Kerrigan



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Hilliard Warehouse Expansion
City of Elmira
Municipal Inspection
October 25, 2021

BY: Jessica Verrigni, CPESC, CPSWQ



Area of relocated storm drainage.



Area where storm drainage was supposed to go.