

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Hilliard Warehouse	<b>Date</b> 4-11-22
<b>Location</b> College Ave , City of Elmira	<b>Permit #</b> NYR111586
<b>Weather Conditions</b> sunny	<b>Entry Time:</b> 10:52 am
<b>On-Site Representative Present:</b> Brian Houghson, Wenzel	<b>Exit Time:</b> 11:14 am

Construction Site Notes:	
	-Swale at front of property along College Ave, had to be constructed differently due to a gas utility line. The swale now splits in two directions and dumps into dry wells.
	-working to complete drainage swale and spread topsoil for final stabilization.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
		X	Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
	-Need copy of updated drawings for the drainage swale changes.
	-Stabilization of idle soil is needed but contractor is actively working on this.

Satisfactory	Marginal	x	Unsatisfactory
<b>Date</b> 4/11/22	<b>Inspector</b> <i>Jessica Arrighetti</i>		



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Hilliard Warehouse  
City of Elmira  
Municipal Inspection  
April 11, 2022


**BY:** Jessica Verrigni, CPESC, CPSWQ



Topsoil for final stabilization.



Observation ports to underground infiltration system.



Trench drain in truck unloading dock.



Silt sock installed around bare exposed soil.



**COUNTY OF CHEMUNG**  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Hilliard Warehouse  
City of Elmira  
Municipal Inspection  
April 11, 2022

**BY:** Jessica Verrigni, CPESC, CPSWQ



1 of 2 Dry wells installed along College Ave side of building.



Shaping drainage swale to convey water to dry wells.

