

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Six67 Apartments	Date 9-24-20
Location College Ave Elmira, NY	Permit # NYR11G564
Weather Conditions sunny	Entry Time: 11:37 am
On-Site Representative Present: NONE	Exit Time: 11:50 am

Construction Site Notes:	
	-Work continues to progress on apartment building.
	-Erosion and sediment control practices have not been maintained in months. I have been unable to locate someone from construction firm managing the site.

Yes	No	N/A		
	X		All erosion and sediment control measures installed/constructed	
	XX		All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
	X		Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
			Was there a discharge into the receiving water on the day of inspection	
			Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
-Silt fence continues to be in disrepair around the entire site. Now there is work occurring in an area completely unprotected by E&S controls.	
-Concrete continues to be washed onto the ground.	

Satisfactory Marginal Unsatisfactory **XX**

Date 9/24/20	Inspector <i>Jessica Carrington</i>
---------------------	--



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT:	Six67 Apartments
	City of Elmira
	MS4 Construction Inspection
	September 24, 2020
BY:	Jessica Verrigni, CPESC, CPSWQ



Work has started in new area of project and no erosion and sediment controls are installed.



Work has started in new area of project and no erosion and sediment controls are installed.



Concrete washed onto the ground.



Silt fence around entire site is in disrepair.