

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Six67 Apartments	Date 11/3/2020
Location College Ave Elmira, NY	Permit # NYR11G564
Weather Conditions overcast, mild	Entry Time: 11:09 am
On-Site Representative Present: No one in construction trailer	Exit Time: 11:22 am

Construction Site Notes:	
	-Building progress is continuing.
	-Silt fence will be replaced with compost sock in the near future. Consulting engineer requested the change.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	SEE NOTE
	X		Are there currently more than 5 acres disturbed w/o prior approval	
		X	Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
	-Silt fence is being encroached upon with building materials. One area has pipe on the fence.

Satisfactory Marginal X -Unsatisfactory

Date 11-3-20	Inspector <i>Jessica Verrugni</i>
---------------------	--




COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Six67 Apartments
City of Elmira
Municipal Construction Inspection
November 3, 2020


BY: Jessica Verrigni, CPESC, CPSWQ



Construction entrance on West side of project is relocated but in good condition.



Silt fence encroached upon by building materials.



Building materials on silt fence.