





COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

<b>PROJECT:</b>	Hilliard Building Expansion
	City of Elmira
	Municipal Inspection
	January 29, 2020
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Underground stormwater system was installed. Does not appear C&D was removed from area as SWPPP was approved.



Manhole diversion structure lid open, soil can get into underground stormwater system.



Closed lid on dry well should be an open grate so water can get into it.

