

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Hilliard Building Expansion	<b>Date</b> 7-14-2020
<b>Location</b> Magee St. Elmira, NY	<b>Permit #</b> NYR11F218
<b>Weather Conditions</b> sunny	<b>Entry Time:</b> 11:44 am
<b>On-Site Representative Present:</b> None	<b>Exit Time:</b> 11:52 am

Construction Site Notes:			
--Project is completed. Awaiting final stabilization and paperwork.			

Yes	No	N/A	
		X	All erosion and sediment control measures installed/constructed
		X	All erosion and sediment control measures maintained properly
		X	Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?


Corrections Needed:			
-Catch basin inserts can be removed from W. 5 <sup>th</sup> street and W. 4 <sup>th</sup> Streets.			

Satisfactory	X	Marginal	Unsatisfactory
<b>Date</b> 7-14-20	<b>Inspector</b> <i>Justina Verinogin</i>		



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

<b>PROJECT:</b>	Hilliard Building Expansion City of Elmira Municipal Inspection July 14, 2020
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Inserts in catch basins on W. 5<sup>th</sup> and W. 4<sup>th</sup> Streets can be removed.

