

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name LECOM	Date 10/15/19
Location Magee Street Elmira (City), NY	Permit # NYR11F218
Weather Conditions sunny	Entry Time: 12:50pm
On-Site Representative Present:	Exit Time: 12:59 pm

Construction Site Notes:			
			-Building is still under construction.
			-Outside looks like it is being prepped for stabilization.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
	X		Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:			
			-Monitor construction entrance onto W. Clinton Street to make sure that sediment does not become an issue by getting tracked onto municipal road.


Satisfactory X Marginal Unsatisfactory

Date 10/15/19	Inspector <i>Jessica Verriggi</i>
----------------------	--



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	LECOM
	City of Elmira
	Municipal Construction Insp.
	October 15, 2019
BY:	Jessica Verrigni, CPESC, CPSWQ



Construction Entrance onto W. Clinton Street has some track out.



Inlet protection around catch basin.



Site being prepped for stabilization.



Inlet protection around underground infiltration drainage structures.