

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name LECOM	Date 12-11-19
Location Park Ave, Elmira (City), NY	Permit # NYR11E617
Weather Conditions sunny, cold	Entry Time: 11:32 am
On-Site Representative Present: none	Exit Time: 11:49 am

Construction Site Notes:

-All site earthwork is completed for the job.
-All areas have been stabilized with SOD

Yes	No	N/A	
		X	All erosion and sediment control measures installed/constructed
		X	All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

-The Water Quality unit in the parking lot has not been grouted correctly.

Satisfactory Marginal Unsatisfactory

Date 12/11/19	Inspector <i>Joseph Verugni</i>
----------------------	--




COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: LECOM
City of Elmira
Municipal Inspection
December 11, 2019

BY: Jessica Verrigni, CPESC, CPSWQ



Parking lot WQ unit is still not grouted correctly.



This catch basin needs to have the insert removed.



All open soil has been sodded.



All open soil has been sodded.