

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> LECOM Expanded Parking	<b>Date</b> 5-21-20
<b>Location</b> West Fifth and College Ave. Elmira, NY	<b>Permit #</b> NYR11B689
<b>Weather Conditions</b> Overcast	<b>Entry Time:</b> 1430 pm
<b>On-Site Representative Present:</b>	<b>Exit Time:</b> 1:52 pm

Construction Site Notes:

	No earth work is being done. Only landscaping is being installed.

Yes	No	N/A		
		X	All erosion and sediment control measures installed/constructed	
		X	All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
See note			Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
?			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

Corrections Needed:

The trucks delivering materials to the site are accessing the parking lot through an unpaved area. It has created a mud tracking into the parking lot and onto West Fifth Street. This should be swept up.

Satisfactory	Marginal	X	Unsatisfactory
<b>Date</b> 5-21-20	<b>Inspector</b> <i>Josce Herron</i>		




**COUNTY OF CHEMUNG**  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

**PROJECT:** LECOM Expanded Parking  
City of Elmira  
Municipal Inspection  
May 21, 2020

**BY:** Jessica Verrigni, CPESC, CPSWQ



Areas between the sidewalk and street have had sod placed on them for stabilization.



Landscaping being installed.



Area where the contractor is accessing the parking lot is creating a mud issue into the parking lot and off onto Fifth street.