



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: CDS Monarch
City of Elmira
Municipal Construction Inspection
May 3, 2018

BY: Jessica Verrigni, CPESC, CPSWQ



Areas that have had severe erosion issues have been filled with hay mulch. This is good for erosion control but does not fix the problem with grading.



Areas that have had severe erosion issues have been filled with hay mulch. This is good for erosion control but does not fix the problem with grading.



Concrete washout needs to be replaced if concrete will be utilized on site again.



Runoff is getting under the compost sock at the north west end of the buildings.




COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: CDS Monarch
City of Elmira
Municipal Construction Inspection
May 3, 2018

BY: Jessica Verrigni, CPESC, CPSWQ



Construction debris and litter are all over the site.



Concrete has been washed off onto the ground.



Stone "donut" around catch basin has been driven on and flattened out. Repair is required.

