

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Dominion LN-31	<b>Date</b> 10-21-20
<b>Location</b> Betewen Prospect Hill and Beers Hill Road Horseheads, NY	<b>Permit #</b> NYR11G793
<b>Weather Conditions</b> foggy	<b>Entry Time:</b> 8:55 am
<b>On-Site Representative Present:</b> Adam Diltz, Dominion	<b>Exit Time:</b> 9:34 am

Construction Site Notes:

-Work is occurring between Beers Hill Road and Prospect Hill. Once this section is completed the company will be shutting down operations for the winter.
-All changes to the SWPPP have been documented in the onsite SWPPPs.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
	X		Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

-No corrections needed at this time.

Satisfactory                          Marginal                      Unsatisfactory

<b>Date</b> 10/21/20	<b>Inspector</b> <i>Jessica Verrigni</i>
----------------------	--



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

PROJECT: Dominion LN-31  
Town of Horseheads  
Municipal Compliance Insp.  
October 21, 2020

BY: Jessica Verrigni, CPESC, CPSWQ



Mats used as a construction entrance.



Mats used as construction entrance.



Silt socks installed at all planned locations.



Area where working outside of LOD and soil stockpile.