

COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Barrington West
Town of Horseheads
Municipal Inspection
January 29, 2020

BY: Jessica Verrigni, CPESC, CPSWQ



Some dry well are filled with water and frozen over.




Construction entrance is installed but traffic for foundation is causing mud to track onto road.



Construction entrance is installed but traffic for foundation is causing mud to track onto road.



Concrete washout needs to be replaced. Liner needs to be staked to the ground better. New washout required before next pour.



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Barrington West
Town of Horseheads
Municipal Inspection
January 29, 2020

BY: Jessica Verrigni, CPESC, CPSWQ



Areas of open soil sitting idle need to have soil stabilization applied.



Soil stockpiles need to have stabilization applied.



Areas of open soil sitting idle need to have soil stabilization applied.



Silt fence needs to be maintained around the site where it is knocked down.