

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Barrington Lot 85 and 86	<b>Date</b> 5-18-20
<b>Location</b> Wexton Court Horseheads, NY	<b>Permit #</b> NYR11F212
<b>Weather Conditions</b> Overcast	<b>Entry Time:</b> 1:54 pm
<b>On-Site Representative Present:</b> Brad Kapral	<b>Exit Time:</b> 2:10 pm


Construction Site Notes:			
			-Lot 86 home under construction

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X	X		Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:			
			-Soil stabilization is needed on Lot 85. Developer is awaiting sod farms to re-open from pandemic.
			-Silt fence needs repair at rear of Lot 85.

Satisfactory                      Marginal                      X                      Unsatisfactory


**Date** 5-18-20                      **Inspector** *Giuseppe Verrigni*



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
**851 Chemung Street**  
**Horseheads, New York 14825**  
**Ph. 607.796.2216**

**PROJECT:** Barrington West Lot 85 & 86  
Town of Horseheads  
Municipal Inspection  
May 18, 2020

**BY:** Jessica Verrigni, CPESC, CPSWQ



Silt fence requires repair.

