

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**




<b>Project Name</b> Barrington West Lot 83 & 84	<b>Date</b> 7-12-2021
<b>Location</b> Wexford Court Horseheads, NY	<b>Permit #</b> NYR11F212
<b>Weather Conditions</b> sunny clear	<b>Entry Time:</b> 11:23 am
<b>On-Site Representative Present:</b> none	<b>Exit Time:</b> 11:45 am

Construction Site Notes:	
	-House on Lot 84 is under construction but both lots 83 and 84 have been cleared and open soil.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
	X		All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
	X		Have stabilization measures been initiated in inactive areas	
		X	Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:
<b>Silt Fence-</b> silt fence needs to be replaced around both lots. It has holes and cannot be salvaged.
<b>Soil Stabilization-</b> All bare soil outside of a 10 foot perimeter of the house needs to be stabilized. Active erosion is occurring to the point it has gone over the silt fence at the rear of the property.
<b>Construction Entrance-</b> driveway pipe is plugged with stone and debris on the upslope side. This is disrupting flow from upslope road drainage.

Satisfactory	Marginal	Unsatisfactory	X
<b>Date</b>	<b>Inspector</b>		



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Barrington West Lot 83 & 84  
Town of Horseheads  
Municipal Construction Insp.  
July 12, 2021

**BY:** Jessica Verrigni, CPESC, CPSWQ



Sediment has overrun the silt fence and left the project location.



Driveway culvert pipe is blocked with stone and veg. debris. This disrupts flows from other areas of the neighborhood.



Silt fence around both lots needs to be replaced with new silt fence. Existing fence has holes and is beat up and cannot be salvaged.



Bare soil outside of a 10' perimeter around the house needs to be temporarily stabilized. Soil is eroding and leaving the site.