

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Barrington West Lot 83 & 84	<b>Date</b> 12/16/2021
<b>Location</b> Wexford Court Horseheads (T)	<b>Permit #</b> NYR11F212
<b>Weather Conditions</b> sunny, cool	<b>Entry Time:</b> 10 :15 am
<b>On-Site Representative Present:</b> Bob Young, Jamie Burgess (Village representative)	<b>Exit Time:</b> 10:20 am

Construction Site Notes:

	Lot 84 house under construction. E&S plan being followed.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	x		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
	x		Was there a discharge into the receiving water on the day of inspection
	x		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

NO ISSUES


Satisfactory                       Marginal                      Unsatisfactory

<b>Date</b> 12/16/21	<b>Inspector</b> <i>Jessica Kerrigan</i>
----------------------	--



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Barrington West Lot 83 & 84  
Town of Horseheads  
Municipal Construction Inspection  
December 16, 2021

**BY:** Jessica Verrigni, CPESC, CPSWQ



All soils stabilized and silt fence functioning.



All soils stabilized and silt fence functioning.



Construction entrance in good shape.



All soils have been stabilized.