

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Barrington West Lot 54	Date 12-16-2021
Location Royal Crest Horseheads (T)	Permit # NYR11F212
Weather Conditions sunny	Entry Time: 10:22 am
On-Site Representative Present: none	Exit Time: 10:30 am

Construction Site Notes:

-Lot just started construction.
-Need contractor E&S certification

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
		X	Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
?			Are weekly inspections being performed?
?			Are the inspections being performed by a qualified individual?

Corrections Needed:

-Need official E&S plan from Fagan Engineers
-Weekly inspections will need to be conducted.
-Need a copy of contractor's 4 Hour Erosion and Sediment Control certification.

Satisfactory	X	Marginal	Unsatisfactory
Date 12/16/21	Inspector <i>Jessica Verrugni</i>		




COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Barrington West Lot 54
Town of Horseheads
Municipal Construction Inspection
December 16, 2021

BY: Jessica Verrigni, CPESC, CPSWQ



Silt fence installed and functioning.



Keep an eye on this spot. It appears that drainage is concentrated here and could cause issues.



Construction entrance installed but need driveway permit from the Town.