

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Barrington West Lot #54	Date 4-11-22
Location Royal Court Horseheads, NY	Permit # NYR11F212
Weather Conditions sunny	Entry Time: 11:45 am
On-Site Representative Present:	Exit Time: 11:54 am

Construction Site Notes:	
-Drainage at the rear of the property continues to be a concern. There is not standing water between the two properties and impervious surfaces don't exist yet.	

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
	X		All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
	X		Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
			Are the inspections being performed by a qualified individual?

Corrections Needed:	
-Silt fence along downslope property requires maintenance.	
-Open soil areas where work is not occurring requires temporary stabilization.	

Satisfactory	Marginal	x	Unsatisfactory
Date 4/11/22	Inspector Jessica Verrigni		



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Barrington West Lot #54
Town of Horseheads
Municipal Inspection
April 11, 2022

BY: Jessica Verrigni, CPESC, CPSWQ




Soil is overtopping the silt fence. Remove soil and repair silt fence.



Silt fence not properly toed into the ground.



Drainage issues already a cause of concern.



Soil is not being actively disturbed at this time-stabilization required.