Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control

Project Name Barrington West Lot 83/84	**Date** 6-2-2022
Location Wexford Court, Horseheads	**Permit #NYR11F212**
Weather Conditions partly sunny	**Entry Time:** 11:06 am
On-Site Representative Present: none	**Exit Time:** 11:15 am

Construction Site Notes:

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
	X		All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X			Have stabilization measures been initiated in inactive areas	
		X	Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:

-Silt fence around lot needs repair in places.

-Construction garbage is blowing around the site and needs to be properly disposed of.

Satisfactory Marginal X Unsatisfactory

Date 6/2/22	**Inspector** Jessica Verrigni

COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	Barrington West Lot 83/84 Town of Horseheads Municipal Construction Insp. June 2, 2022
BY:	Jessica Verrigni, CPESC, CPSWQ