

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**




Project Name Barrington Lot 54	Date 8/3/2022
Location Wexford Court Horseheads, NY	Permit # NYR11f212
Weather Conditions sunny	Entry Time: 9:36 am
On-Site Representative Present: Brad Kapral	Exit Time: 9:47 am

Construction Site Notes:	
	-No changes or improvements since 6-28-22 municipal inspection.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
	X		Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
			Are the inspections being performed by a qualified individual?

Corrections Needed:	
-Soil needs to be stabilized around the entire lot. Erosion is occurring and sediment is stacking up behind the silt fence.	


Satisfactory	Marginal	Unsatisfactory	x
Date 8/3/22	Inspector <i>Jessica Verrucchi</i>		



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Barrington West Lot 54
Town of Horseheads
Municipal Inspection
August 3, 2022

BY: Jessica Verrigni, CPESC, CPSWQ



Construction entrance is functioning.



Open soil needs to be stabilized to prevent erosion.



Open soil needs to be stabilized to prevent erosion.



Open soil needs to be stabilized to prevent erosion.