

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Barrington Lot 83 & 84	Date 8/3/2022
Location Wexford Court Horseheads, NY	Permit # NYR11f212
Weather Conditions sunny	Entry Time: 9:28 am
On-Site Representative Present: Brad Kapral	Exit Time: 9:35 am

Construction Site Notes:

-Home is under construction but no earth work is being completed at this time.


Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
			Are the inspections being performed by a qualified individual?

Corrections Needed:

-Silt fence along Lot 83 can be removed. Grass is growing, there is no construction on this lot and silt fence is not necessary at this time. Once construction of Lot 83 occurs the fence will need to be re-installed.

Satisfactory Marginal Unsatisfactory

Date 8/3/22 **Inspector** *Jessica Vermeulen*



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Barrington West Lot 83 84
Town of Horseheads
Municipal Inspection
August 3, 2022

BY: Jessica Verrigni, CPESC, CPSWQ



Silt fence along Lot 83 can be removed. The grass is growing and there is no active earth disturbance.

