

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Barrington West Lot 54	Date 9-14-2022
Location Wexford Court, Horseheads, NY	Permit # NYR11F212
Weather Conditions sunny	Entry Time: 11:27 am
On-Site Representative Present: None	Exit Time: 11:35 am

Construction Site Notes:	
	-Work continues on the house inside and out. Work has been done outside with the installation of a deck and siding.
	NOTE: Soil has been heavily compacted and eroded throughout the construction process. As a reminder Soil restoration and Decompaction is required of this site prior to final land grading.

Yes	No	N/A	
	X		All erosion and sediment control measures installed/constructed
	X		All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
	X		Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:
-Silt fence requires maintenance where utilities were installed underneath it.
-Stabilization of soils is required. This is for temporary to prevent erosion.
-Pollution and Spill prevention- Paint/grout washed onto the ground. This is not acceptable. Dumpster is leaking some sort of juice from paint or some material onto the ground which is graded to the municipal ditch.

Satisfactory	Marginal	Unsatisfactory X
Date 9/14/22	Inspector Jessica Arrigoni	



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	Barrington West Lot 54
	Town of Horseheads
	Municipal Inspection
	September 14, 2022
BY:	Jessica Verrigni, CPESC, CPSWQ



Silt fence requires repair where utilities were installed under it.

Erosion continues to be an issue because the soil has never been temporarily stabilized to prevent it from happening.



Soil heavily compacted will require decopaction and restoration prior to final topsoiling and landgrading.

Dumpster is leaching some sort of pollutant onto the ground. This area grades towards ditch.