

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**




<b>Project Name</b> Barrington West Lot 83 & 84	<b>Date</b> 9-14-2022
<b>Location</b> Wexford Court, Horseheads, NY	<b>Permit #</b> NYR11F212
<b>Weather Conditions</b> sunny	<b>Entry Time:</b> 11:19 am
<b>On-Site Representative Present:</b> None	<b>Exit Time:</b> 11:25 am

Construction Site Notes:	
	Lot 84 home is complete and in the process of having sod installed.
	Lot 83 has been cleaned up and appears to be where materials and equipment will be stored. Driveway pipe was installed but no permit was obtained from the Town Highway Dept.

Yes	No	N/A		
		X	All erosion and sediment control measures installed/constructed	
		X	All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X			Have stabilization measures been initiated in inactive areas	
		X	Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
-All open soil areas need to be stabilized. This includes Lot 84 and Lot 83 as well as areas around dry wells.	

Satisfactory	X	Marginal	Unsatisfactory
<b>Date</b> 9/14/22	<b>Inspector</b> Jessica Verrugni		



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

**PROJECT:** Barrington West Lot 83  
Town of Horseheads  
Municipal Inspection  
September 14, 2022

**BY:** Jessica Verrigni, CPESC, CPSWQ



Final grading and topsoiling has been completed.



Bare soil around dry well needs to be stabilized.



Sod is being placed to stabilize the lot.



Driveway pipe installed on Lot 83 without highway department permit.