

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Hickory Grove Solar Project	<b>Date</b> 11/3/2020
<b>Location</b> Hickory Grove Road Horseheads, NY	<b>Permit #</b> NYR11F809
<b>Weather Conditions</b> overcast	<b>Entry Time:</b> 1:54 pm
<b>On-Site Representative Present:</b> None	<b>Exit Time:</b> 2:16 pm

<b>Construction Site Notes:</b>			
			-Contacted T. Stubbs via cell when inspection was completed.
			-Discussed the need to provide soil restoration and soil stabilization to all areas that have been over driven by vehicles throughout construction.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
			Are there currently more than 5 acres disturbed w/o prior approval	
X	X		Have stabilization measures been initiated in inactive areas	SEE NOTE
	X		Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

<b>Corrections Needed:</b>			
Soil stockpile requires stabilization.			

Satisfactory	X	Marginal	Unsatisfactory
<b>Date</b>	11/3/20	<b>Inspector</b>	Jessica Verrucchi



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

<b>PROJECT:</b>	Hickory Grove Solar Project Town of Horseheads Municipal Construction Inspection November 3, 2020
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Construction entrance in okay shape but will need fresh stone soon.



Areas overdriven during construction will require soil restoration and stabilization.



Areas overdriven during construction will require soil restoration and stabilization.



Areas overdriven during construction will require soil restoration and stabilization.



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

<b>PROJECT:</b>	Hickory Grove Solar Project Town of Horseheads Municipal Construction Inspection November 3, 2020
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Areas overdriven during construction will require soil restoration and stabilization.



Areas overdriven during construction will require soil restoration and stabilization.



Areas overdriven during construction will require soil restoration and stabilization. Soil stockpile should be stabilized.



Areas overdriven during construction will require soil restoration and stabilization.