



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	Dollar General
	Town of Horseheads
	Municipal Inspection
	August 26, 2019
BY:	Jessica Verrigni, CPESC, CPSWQ



Silt fence has been installed around the perimeter.



Concrete washout is 100% full and concrete has been washed onto the ground next to washout pit.



Soil stockpile is partially covered with plastic. It either has to be completely covered or temporarily stabilized.



Soil stockpile is partially covered with plastic. It either has to be completely covered or temporarily stabilized.