

---

851 Chemung Street  
Horseheads, New York 14845

May 24, 2018

ATTN: Thomas Skebey, Code Enforcement Officer/Stormwater Management Officer  
Town of Horseheads  
150 Wygant Road  
Horseheads, NY 14845

**RE: Scotch Pine Lane Housing Development  
Erosion and Sediment Control Plan Acceptance**


Mr. Skebey,

I have completed a cursory review of the Scotch Pine Lane Housing Development Erosion and Sediment Control Plan dated May 2018 and revised May 22, 2018. Based upon my review of the above information, I believe that the proposed erosion and sediment control plan is consistent with the Town Horseheads' Stormwater Management and Erosion and Sediment Control Ordinance. This acceptance is based upon the following condition:

1. Silt and/or sediment shall not be allowed to leave the project site, including tracking onto public streets. Erosion and sediment controls, outlined in the accepted Erosion & Sediment Control Plan, shall be implemented and maintained to ensure this purpose. If silt, sediment, and/or dust are found to be leaving the site, the Owner (or their contractor) shall take immediate actions to correct the situation.
2. One set of the Final Erosion and Sediment Control Plan must be on-site at all times during construction and site stabilization.
3. Owner/Contractor shall not disturb greater than 5 acres at one time without seeking additional authorization to do so.

If you have any questions or comments regarding this letter, please do not hesitate to contact me. Furthermore, I would be happy to meet to discuss this subject in greater detail.

Sincerely,



Jessica Verrigni, CPESC, CPSWQ

Cc: Jimmie Joe Carl, Chemung County Stormwater  
Marc Maser, Maser Engineering