

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Glad Tidings Building Exp	Date 6-26-18
Location 116 Breesport Rd Horseheads, NY	Permit # NYR11C743
Weather Conditions Sunny, warm	Entry Time: 11:30
On-Site Representative Present: Curtis, church rep.	Exit Time: 11:45

Construction Site Notes:	
	-Grading work has been completed. Waiting for grass to grow
	-All work is occurring on the building right now.

Yes	No	N/A	
<input checked="" type="checkbox"/>			All erosion and sediment control measures installed/constructed
<input checked="" type="checkbox"/>			All erosion and sediment control measures maintained properly
		<input checked="" type="checkbox"/>	Are there currently more than 5 acres disturbed w/o prior approval
<input checked="" type="checkbox"/>			Have stabilization measures been initiated in inactive areas
<input checked="" type="checkbox"/>			Are permanent stormwater control measures being implemented
	<input checked="" type="checkbox"/>		Was there a discharge into the receiving water on the day of inspection
	<input checked="" type="checkbox"/>		Evidence of turbidity or oil in the receiving waters
<input checked="" type="checkbox"/>			Are weekly inspections being performed?
<input checked="" type="checkbox"/>			Are the inspections being performed by a qualified individual?

Corrections Needed:	
	-Drainage swale along east side of property should be seeded and mulched to get it stabilized.

Satisfactory <input checked="" type="checkbox"/>	Marginal	Unsatisfactory
Date 6-26-18	Inspector <i>Yvonne Verigni</i>	



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	Glad Tidings Church Town of Horseheads Municipal Construction Inspection June 26, 2018
BY:	Jessica Verrigni, CPESC, CPSWQ




Drainage swale along the east side of property needs to be seeded and mulched.



Rock outlet protection into the forebay.



Infiltration basin



Infiltration basin emergency spillway.