

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Glad Tidings Building Exp	Date 12-5-18
Location 116 Breesport Rd Horseheads, NY	Permit # NYR11A108
Weather Conditions Overcast cold	Entry Time: 11:33 am
On-Site Representative Present: Curtis- Journey Center	Exit Time: 11:50 am

Construction Site Notes:	
	-No active construction at this time. Work continues on the building.
	-Paving is completed.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
	X		All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X	X		Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
	-Mud has been tracked over the entire previously paved area. Cars are parking in it, driving in it and tracking it onto Breesport Rd.
	-Stockpile area is still being utilized and mud is being tracked from that onto the new parking area.
	-This site is not eligible for winter shutdown at this time.

Satisfactory	Marginal	X	Unsatisfactory
Date 12-5-18	Inspector <i>Janice Verigin</i>		



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	Villa's at Gardner Rd. Village of Horseheads Municipal Construction Inspection December 5, 2018
BY:	Jessica Verrigni, CPESC, CPSWQ



Mud is being tracked onto the old paved driveway. This mud is not part of the limits of disturbance. It is being tracked down Breesport Road.



Stockpile area is not stabilized and is still being used.



Mud is being tracked from stockpile area

