



Project Name Fairport Ridge	Date 11-30-17
Location Prospect Hill Horseheads NY	Per mit #NYR11B687
Weather Conditions Sunny, breezy	Entry Time: 10:41
On-Site Representative Present: Scott Masso,owner/contractor	Exit Time: 11:16

Construction Site Notes:

-3 buildings are under construction
-leach field and septic tanks being installed.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
X	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

-add silt fence around topsoil pile. mulch pile 4 tools per acre as discussed on site.
-as septic tanks are completed male sure to mulch and crimp in as discussed.

Satisfactory <input checked="" type="checkbox"/>	Marginal <input type="checkbox"/>	Unsatisfactory <input type="checkbox"/>
Date 11/30/17	Inspector Jessica Verigni	



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216


<b>PROJECT:</b>	Fairport Ridge Subdivision
	Town of Horseheads
	Municipal Inspection
	November 30, 2017
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Soil stockpile is being utilized to backfill leach field at this time. Once completed the pile will be seeded and mulch to winter rates.



Construction Entrance Installed looks good.



Septic tanks are being installed, covered and stabilized.

