

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Fairport Ridge	Date 9-4-18
Location Prospect Hill Horseheads, NY	Permit # NYR11B687
Weather Conditions Sunny, hot, humid	Entry Time: 1:42 pm
On-Site Representative Present: None	Exit Time: 2:09 pm

Construction Site Notes:

-Contractor working on installed water lines and sewer at this time. Buildings continue to be under construction	

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
			Are weekly inspections being performed? Not certain- havent been copied on any recently
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

-2nd Construction Entrance- if heavy construction traffic continues to utilize area at south end of property for entry then a second construction entrance is suggested.

Satisfactory Marginal Unsatisfactory

Date 9-4-18	Inspector <i>James Verrigni</i>
--------------------	----------------------------------------