

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Fairport Ridge	Date 10-15-18
Location Prospect Hill Horseheads, NY	Permit # NYR11B687
Weather Conditions Overcast, cool	Entry Time: 12:07 pm
On-Site Representative Present: Scott Masso-owner/contractor	Exit Time: 12:57 pm

Construction Site Notes:

	-Construction inside of the buildings continues.
	-Water line is currently being installed.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
	X		All erosion and sediment control measures maintained properly	Silt fence
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X			Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:

-Silt fence needs to be re-installed around soil stockpile.
-Continue to stabilize areas that are no longer being graded or sit idle greater than 14 days.

Satisfactory ^X Marginal Unsatisfactory

Date 10-15-18	Inspector <i>James Verigin</i>
----------------------	---------------------------------------



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Fairport Ridge
Town of Horseheads
Municipal Construction Inspection
October 15, 2018

BY: Jessica Verrigni, CPESC, CPSWQ



Construction entrance functioning.



Silt fence needs to be re-installed around the soil stockpile.



Water line is being installed.



Septic field has been seeded and mulched.