

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Fairport Ridge	<b>Date</b> 12-5-18
<b>Location</b> Prospect Hill Horseheads, NY	<b>Permit #</b> NYR11B687
<b>Weather Conditions</b> Overcast; cold	<b>Entry Time:</b> 10:31 am
<b>On-Site Representative Present:</b> Robert Hartung, Phoenix Construction Gary- Bergmann	<b>Exit Time:</b> 10:56 am

**Construction Site Notes:**

-Many buidlings are under construction. The bulk of work is occuring inside of the building at this time.
-Contractor has said he will probably not be doing any further earth disturbance this year.
-Soil stockpiles have been stabilized.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
	X		All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

**Corrections Needed:**

Consturction entrance requires maintenance. All of the voids in the stone have been filled. Top construction entrance with another layer of stone according to the plan.

Satisfactory                      Marginal X                      Unsatisfactory

<b>Date</b> 12-5-18	<b>Inspector</b> <i>Juanita Verrigni</i>
---------------------	--



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

**PROJECT:** Fairport Ridge Subdivision  
Town of Horseheads  
Municipal Construction Inspection  
December 5, 2018

**BY:** Jessica Verrigni, CPESC, CPSWQ



Construction entrance requires maintenance.



Construction entrance requires maintenance.



Overview of site.



Overview of site.