

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Fairport Ridge	Date 5-15-2019
Location Prospect Hill Horseheads, NY	Permit # NYR11B687
Weather Conditions sunny, warm	Entry Time: 11:14 am
On-Site Representative Present: Scott Masso	Exit Time: 11:45 am

Construction Site Notes:

-Road is being brought to grade in the first phase of the project.
-Work continues on the buildings
-Stormwater forebay will be constructed shortly

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
	X		All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

- Silt fence needs to be replaced around soil stockpile.
- Soil stockpile needs to be stabilized.

Satisfactory Marginal X Unsatisfactory

Date 5/15/19 Inspector Jessica Verrigno



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Fairport Ridge
Town of Horseheads
Municipal Construction Insp.
May 15, 2019

BY: Jessica Verrigni, CPESC, CPSWQ



Additional construction entrance has been added.



Topsoiling has started in preparation of stabilization with seed and mulch.



Silt fence needs to be replaced.



Topsoil pile requires stabilization.