

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Fairport Ridge	Date 8-1-19
Location Prospect Road Horseheads (T), NY	Permit # NYR11B689
Weather Conditions sunny	Entry Time: 8:59 am
On-Site Representative Present: Scott Mosso-owner	Exit Time: 9:10 am

Construction Site Notes:

	-Earth work is being done on stormwater basin.

Yes	No	N/A		
x			All erosion and sediment control measures installed/constructed	
	x		All erosion and sediment control measures maintained properly	
	x		Are there currently more than 5 acres disturbed w/o prior approval	
x			Have stabilization measures been initiated in inactive areas	
x			Are permanent stormwater control measures being implemented	
	x		Was there a discharge into the receiving water on the day of inspection	
	x		Evidence of turbidity or oil in the receiving waters	
x			Are weekly inspections being performed?	
x			Are the inspections being performed by a qualified individual?	

Corrections Needed:

-If pile of soil from strowmater basin remains idle for 14 days or longer then it will need to be temporarily stabilized.

Satisfactory Marginal Unsatisfactory


Date	Inspector
-------------	------------------



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Fairport Ridge
Town of Horseheads
Municipal Construction Inspection
August 1, 2019

BY: Jessica Verrigni, CPESC, CPSWQ



New construction entrance has been installed.



All areas sitting idle have been temporarily stabilized and are growing grass.



Stormwater basin under construction.



If topsoil pile remains idle then temporary stabilization will be required.