

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Fairport Ridge	Date 10-21-19
Location State Prospect Hill Horseheads (T), NY	Permit # NYR11B689
Weather Conditions sunny	Entry Time: 1:22 pm
On-Site Representative Present: Scott Mosso-owner	Exit Time: 2:01 pm

Construction Site Notes:

-Catch basins and stormwater drainage being constructed.
-Stormwater basin partially constructed

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
X			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Corrections Needed:

-large area around stormwater basin is open and exposed. If work doesn't continue this area will need to be stabilized.
-no major issues

Satisfactory Marginal Unsatisfactory

Date 10/21/19 Inspector Jessica Veragiu



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Fairport Ridge
Town of Horseheads
Municipal Inspection
October 21, 2019

BY: Jessica Verrigni, CPESC, CPSWQ



Stormwater basin under construction.



Storm sewer discharge to stormwater basin.



Storm sewer and catch basins are being installed.



Areas around the houses have been stabilized.