


**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Fairport Ridge	<b>Date</b> 6-10-20
<b>Location</b> Prospect Hill Road Horseheads, NY	<b>Permit #</b> NYR11B687
<b>Weather Conditions</b> sunny warm	<b>Entry Time:</b> 9:06 am
<b>On-Site Representative Present:</b> Scott Mosso	<b>Exit Time:</b> 9:50 am


<b>Construction Site Notes:</b>			
			-No construction occurring at this time.

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
x			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
x	x		Have stabilization measures been initiated in inactive areas	
x			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

<b>Corrections Needed:</b>			
-Catch basin protection is required around the two closest to the blacktop. Photos submitted from contractor-work completed.			
-Area behind the first house built needs stabilization.			
-Side slope of pond is eroding. Protections need to be placed to keep the sediment out and stop the erosion. Photos submitted from contractor-work completed.			

Satisfactory                      Marginal                      X                      Unsatisfactory

<b>Date</b> 6-10-20	<b>Inspector</b> Jessica Verrigni
---------------------	-----------------------------------



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

<b>PROJECT:</b>	Fairport Ridge
	Town of Horseheads
	Municipal Inspection
	June 10, 2020
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Catch basin needs protection around it.



Catch basin needs protection around it.

