

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Fairport Ridge	Date 6-2-2022
Location Prospect Hill, Horseheads (T)	Permit # NYR11B689
Weather Conditions overcast	Entry Time: 1:50 PM
On-Site Representative Present: none	Exit Time: 1:56 PM

Construction Site Notes:	
	-No active construction.
	-Stormwater basin needs to be finished.
	-What is happening with the piles of soil around the property?

Yes	No	N/A		
		X	All erosion and sediment control measures installed/constructed	
		X	All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X	X		Have stabilization measures been initiated in inactive areas	See note
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

Corrections Needed:	
	-Soil piles are all around the property. What is the plan with these? Are they to finish the project? The piles and open bare areas should be stabilized if they will be there for longer.
	-Stormwater basin still needs to be finished.

Satisfactory	X	Marginal	Unsatisfactory
Date 6/2/22	Inspector <i>Jessica Carrigini</i>		



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Fairport Ridge
Town of Horseheads
Municipal Construction Insp.
June 2, 2022

BY: Jessica Verrigni, CPESC, CPSWQ



Soil stockpiles and open bare soil need to be stabilized.



Stormwater basin appears to be unfinished.



Open bare soil will need to be stabilized.

