

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Hunter's Run	Date 10/17/19
Location Sing Sing Rd Horseheads, NY	Permit # NO PERMIT
Weather Conditions overcast, rainy	Entry Time: 11:21 am
On-Site Representative Present: none	Exit Time: 11:28 am

Construction Site Notes:


-Property has been graded open and road is being cut in.

Yes	No	N/A		
	X		All erosion and sediment control measures installed/constructed	
		X	All erosion and sediment control measures maintained properly	
?			Are there currently more than 5 acres disturbed w/o prior approval	Possibly
	X		Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
	X		Are weekly inspections being performed?	
	X		Are the inspections being performed by a qualified individual?	

Corrections Needed:

Satisfactory Marginal Unsatisfactory **X**

Date 10/17/19	Inspector <i>Jessica Verrigan</i>
----------------------	--



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: Hunter's Run
Town of Horseheads
Municipal Construction Insp.
October 17, 2019

BY: Jessica Verrigni, CPESC, CPSWQ



Construction entrance onto Sing Sing Rd. installed.



Road cut in over to Steeple Chase.



Construction entrance on Steeple Chase side of project installed.



Large area disturbed.